

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **METRO COOLAIRE TRADING CORPORATION**

IAR No: 25-07-0882

P.O No.: **VSU-GOODS-25-22-072 (STF)**

Date: 2025-07-21

Office/Dept: **DCST**

129,915.00

STF-2024-10-02547

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	unit	Aircon, Window Type, 2HP Inverter, KOPPEL: KV18WR-ARF31A	3	3	2025-07-18 #: DR-0300/INV-0114	0	Completed

Specification:

Specifications

- **Type:** 2.0 HP Inverter Window Type
- **Refrigerant:** R32
- **Cooling Capacity:** 18,750 kJ/h
- **Power Source:** 230V, 60Hz, 1Ø
- **Current:** 7.3 A
- **Input Power:** 1,563 W
- **EER Rating:** 12.0 kJ/hW
- **Recommended Floor Area:** 23 – 33 m²
- **Moisture Removal:** 2.8 L/h
- **Noise Level (Indoor):** 51 / 48 dB(A) (H / L)
- **Air Circulation (Indoor):** 14.2 m³/min
- **Air Circulation (Outdoor):** 23.0 m³/min

Features

- High Energy Efficiency Ratio
- All-DC Motor
- Room Temperature Display & Setting
- Air Swing Control
- Filter Clean Indicator
- Timer: 12-Hour On/Off
- Modes: Auto / Cool / Dry / Powerful / Sleep / Quiet
- Blue Fin Condenser (Anti-Corrosion Fin)
- Anti-Bacterial Filter
- Wireless Remote Control
- Random Auto Restart

Installation

- Free Installation

INSPECTION

Date Inspected: 7/21/25

- ☐ Inspected, verified and found in order as to quantity and specifications
- ☐ Others: _____
- _____
- _____


CLINT C. SARVIDA
Inspector

ACCEPTANCE

Date Received: 7/21/25

- ☒ Complete
- ☐ Partial


VIVIAN V. BALBARINO
Head, Supply & Property Management