

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **BAYBAY PRINTSHOP**
P.O No.: **VSU-GOODS-25-22-066 (IGP)**
Office/Dept: **Assorted Depts/Offices**

IAR No: 25-07-0843
Date: 2025-07-09
67,900.00 Assorted PR's

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	set	Air Condition, Split type, Inverter, 1.5 HP, SAMSUNG AR13BYHAMWKNTC <div>Distribution VSUH c/o Normalyn M. Ardiente (IGP-2024-10-01938) - 1</div>	1	1	2025-07-09 #: DR-250709A/SI-5393	0	Completed

Specification:

- **Type:** Inverter, Split
- **Capacity:** 1.5 HP
- **Wattage:** 1250 Watts
- **EER Rating:** 14.26
- **Cooling Capacity:** At least 12,500 kJ/hr
- **Features:**
 - WindFree Technology
 - Digital Inverter Boost
 - Fast Cooling
 - Easy Filter Plus
 - DuraFin
 - Triple Protector Plus
 - Quiet Mode
 - Single User Mode
- **Refrigerant:** R32
- **Includes:**
 - Remote control
 - Mounting bracket
 - 12x Tapping screws
 - 4x Rubber feet (Outdoor package)
 - 2x Remote control batteries
 - Free installation
 - One-year warranty on parts and services
- **Mounting:** Wall mounted
- **Energy Efficiency:** EER rating above 10

2	unit	Aircon, Window Type, 2HP, Non-inverter, PANASONIC CW-N1820EPH <div>Distribution ODCCE c/o Mark Vincent G. Bonje (IGP-2024-10-02758) - 1</div>	1	1	2025-07-09 #: DR-250709A/SI-5393	0	Completed
---	------	---	---	---	-------------------------------------	---	-----------

Specification:

Performance:

- **Cooling Capacity:** 2.0 HP (19,100 kJ/h)
- **Power Input:** 1,680 W
- **EER:** 11.4 kJ/hW
- **Noise Level (Indoor, Low):** 48 dB(A)

Specifications:

- **Power Source:** 230 V, 1Ø Phase, 60 Hz
- **Refrigerant:** R32
- **Type:** Non-Inverter
- **Fan Speed:** 2 speeds

Features:

- **Condensate Removal:** Automatic
- **Air Deflection:** 4-way
- **Chassis:** Slide-out
- **Grille:** Removable and washable intake grille
- **Air Filter:** Easy to clean

with free installation

INSPECTION *slahs*

ACCEPTANCE *slahs*

Date Inspected:

Date Recieved:

- ☐ Inspected, verified and found in order
as to quantity and specifications

☒ Complete

☐ Others: _____

☐ Partial

Clint C. Sarvida
CLINT C. SARVIDA
Inspector

Vivian V. Balbarino
VIVIAN V. BALBARINO
Head, Supply & Property Management