

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **METRO COOLAIRE TRADING CORPORATION**
P.O No.: **VSU-GOODS-25-22-074 (STF)**
Office/Dept: **DFS**

IAR No: 25-07-0883
Date: 2025-07-21
522,000.00 STF-2025-01-00033

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	unit	Floor mounted Air-conditioning Unit, 3 ton, MIDEA: MFSI/0-36CDN8-MD3	6	6	2025-07-18 #: DR-0304/INV-0118	0	Completed

Specification:

3 ton floor mounted Aircondition unit single phase power supply, 1 year warranty and free installations.

Cooling Capacity (kJ/hour)-37,000 (13,100-39000)

Power Input (w) - 3,900 (1,480-4,400)

Indoor Unit Net Weight (kg)- 42.5

Indoor Unit (w x h x d) in mm- 508 x 1,806 x 288

Indoor Unit Packing (w x h x d) in mm- 590 x 1,910 x 382

Outdoor Unit Net Weight (kg) - 91

Outdoor Unit (w x h x d) in mm- 936 x 722 x 336

Refrigerant (Type/kg)- R410A

Piping Liquid / Gas Side (mm)- 9.52/ 15.9

Max Refrigerant Pipe Length- 30

Power Supply (V-Ph-Hz)- 230/ 1/ 60

Indoor Noise Level-Hi/Mi/Lo(db/a)- 61/ 58/ 55

INSPECTION

ACCEPTANCE

Date Inspected: 7/21/15

Date Received: 7/21/15

☐ Inspected, verified and found in order
as to quantity and specifications

☒ Complete

☐ Others: _____

☐ Partial


CLINT C. SARVIDA
Inspector


VIVIAN V. BALBARINO
Head, Supply & Property Management