Republic of the Philippines

VISAYAS STATE UNIVERSITY

Visca, Baybay City, Leyte

SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: P.O No.:

NOLAS COMMERCIAL

PO-GF-MOOE-2025-05-0286

Office/Dept: ICTMC

IAR No:

25-07-0853

Date:

2025-07-09

40,180.00

GF-2025-01-00064

No.	UNIT	DESCRIPTION	Quantity		Date		
<u> </u>			Per P.O	Actual	Received	Balance	Remarks
1	unit	Battery Tester/Analyzêr	1	1	2025-06-24 #: DR- 11621/CI- 004137	0	Completed

Specification:

- Digital Analyzer Tester
- LCD display
- Type of measurement: CCA, IR, SoC and SOH
- Multi battery type: AGM, GEL, STD, Lead Acid,
- 12V/24V Battery
- 1 year warranty

2	unit	Battery, LiFePO4	2	2	2025-07-08 #: DR- 11636/CI- 004147	0	Completed	
---	------	------------------	---	---	---	---	-----------	--

Specification:

- 12 voits
- 20 Ah
- Nominal Capacity: 20ah 0.2 C
- Cycle Life:> 4000 Cycles at 0.2 ?; End-of-Life Capability
- Charging Voltage: 14.6±0.2V
- Charger Current: 4A
- Maximum Charging Current: 10.0
- Discharge Current: 4A
- Maximum Current Duration: 20A
- Discharge Cut-off Voltage: 10.0V
- Shell Material: ABS
- Size (L/Ft/H):180-200mm*75-80mm * 170-185mm

	3	unit	Sealed Lead Acid Battery (VRLA)	4	4	2025-06-24 #: DR- 11621/CI-	0	Completed
-						004137		

4 u	nnit Smart Battery Charger, 12V/24V, 25A/15A	2	2	2025-07-08 #: DR- 11636/CI- 004147	0	Completed
Spe	ecification:					
	 Compatible type of battery: Lead Acid, AGM GEL, LiFe Intelligent Multiple Protection: Over heat protection, Over protection, reverse connect protection, overvoltage profession. Multi Stage automatic charging: 1-Stage: Battery desured stage: Absorption charge, 5-stage: Battery test, 6-stage stage: Re-start charge after battery discharged. Input voltage: 100-240V AC, 50-60Hz Rated output: 12V 25A, 24V 15A Battery Range: 5-400Ah Compliant standards: CE, FCC, UKCA Colored Digital display indicator With Booster Mode US Plug type (AC) 1 year warranty 	vercurrent pro stection, Low Iphation, 2-sta	voltage protec age:Soft start	tion and fire prot charge, 3-stage:	ection. Bulk ch	narge, 4-
NSPE	CTION	ACC	CEPTANCE			
	nspected: Alahy	Date	e Recieved:	Haty		
	Inspected, verified and found in order as to quantity and specifications Others:		•	Complete Partial		
	JUDE B. ROLA Inspector		IAN V. BALI	SARINO ty Managemen	·	

JUDE B. ROLA Inspector