

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **BAYBAY PRINTSHOP**
P.O No.: **VSU-GOODS-25-44-381 (GF-CO)**
Office/Dept: **DBS**

IAR No: 25-11-1536
Date: 2025-10-23
65,200.00 GF-2025-06-00717

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	unit	Aircon, Split Type, 2.5HP (Inverter), CARRIER FP-53CACO24308	1	1	2025-10-22 #: DR 251022A/ SI 5420	0	Completed

Specification:

Features

- High-Density Dust Filter
- Smooth Frequency Control
- Gold Fin Protection
- Silver Ion Filter
- Sleep Mode
- Turbo Mode
- Louver Position Memory
- Fast Cooling
- Includes Remote Control

Specifications

- 2.5HP Inverter
- Cooling Capacity: 23,200 (2,811-23,600) kJ/hr
- Power Supply: 230V, 1Ph, 60Hz
- Power Input: 2,000 (215-2,065) W
- CSPF: 5.2
- Refrigerant: R32
- Sound Level: 48/43/40 dB(A) (H/M/L)
- Dimensions: 24.4 cm (L) x 108.3 cm (W) x 33.6 cm (H)

Warranty and Installation

- 1-Year Warranty
- Free Installation

INSPECTION

ACCEPTANCE

Date Inspected: 10/23/12

Date Recieved: 10/23/12


☒ Inspected, verified and found in order
as to quantity and specifications

☒ Complete

☐ Others: _____

☐ Partial


CLINT C. SARVIDA
Inspector


DOREEN B. ALBA
Head, Supply & Property Management