

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **UNI-REAL TRADING CORPORATION** IAR No: 25-10-1328
P.O No.: **VSU-GOODS-25-28-282-B (STF)** Date: 2025-09-18
Office/Dept: **PPO** 577,038.00 STF-2024-11-03188

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	unit	Transformer, distribution, 50 KVA, DONG-A KOREA	3	3	2025-09-17 #: DR 56488/ CI 223854	0	Completed

Specification:

<!--td {border: 1px solid #cccccc;}br {mso-data-placement:same-cell;}-->

Winding: Cu-Cu (Copper-Copper)

Core: Amorphous or silicon

Primary Voltage: 8 kV with changer

2-2 ½ % above rated primary voltage


2-2 ½ % below rated primary voltage

Bushings: Double bushing

Secondary Voltage: 120/240 Volts with center tap

Mounting: Pole mounted

INSPECTION	ACCEPTANCE
Date Inspected: 9/18/25	Date Recieved: 9/18/25
☒ Inspected, verified and found in order as to quantity and specifications	☒ Complete
☐ Others: _____	☐ Partial

 CLINT C. SARVIDA Inspector	 DOREEN B. ALBA Head, Supply & Property Management