

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **BAYBAY PRINTSHOP** IAR No: 25-11-1534
P.O No.: **VSU-GOODS-25-44-384 (STF-CO)** Date: 2025-10-23
Office/Dept: **Assorted Depts/Offices** 426,950.00 Assorted PR's

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	piece	3 Ton Floor-Mounted Split Type Inverter Aircon, KOPPEL KV36FM-ARF31 <div>Distribution ULC c/o Maegan Lou A. Aruta (STF-2024-10-02472) - 3</div>	3	3	2025-10-22 #: DR 251022C	0	Completed

Specification:

Power Supply:

1 PH / 230 V / 60 Hz

Nominal Capacity:

4.0 HP / 3 TR

Cooling Capacity:

38,201 kJ/h

Rated Current:

14 A

Rated Power:

3,200 W

Energy Efficiency Ratio (EER):

11.9 kJ/h-W

Refrigerant:

Type: R-410A

Charge: 2,500 g

Copper Tube Size:

- Low Side: 3/4"
- High Side: 1/2"

Warranty

- 1 Year on Parts and Service
- 5 Years on Compressor
- Free Installation and accessories included

2	unit	Aircon Floor Mounted airconditioner, KOPPEL KV36FM-ARF31 Distribution _____ DFST c/o Pearl P. Vistal (STF-2024-07-01394) - 1	1	1	2025-10-22 #: DR 251022C	0	Completed
---	------	--	---	---	--------------------------------	---	-----------

Specification:

Floor Mounted Air-Conditioner

Specifications

- **Type:** Floor Mounted Inverter
- **Capacity:** 4 HP (3 TR)
- **Cooling Capacity:** at least 36,100 kJ/h
- **Power Supply:** 230V, 1 Ph, 60 Hz
- **Refrigerant:** R410A or R32
- **System Power Input:** at least 3,200 W
- **EER:** at least 9.5 kJ/W-hr
- **System Current:** at least 16 A

Dimensions and Weight

- **Indoor Unit:**
 - **Dimensions:** 508 x 288 x 1,806 mm
 - **Weight:** 42.5 kg
 - **Sound Level:** High/Med/Low 60/57/54 dB(A)
- **Outdoor Unit:**
 - **Dimensions:** 936 x 336 x 722 mm
 - **Sound Level:** 68 dB(A)

Installation and Services

- **Installation:** Free (including paraphernalia)
- **Post Installation Services:** Included
- **Authorized Service Center:** Within 45-55 km radius from VSU

INSPECTION

Date Inspected:

10/23/25

- ☒ Inspected, verified and found in order as to quantity and specifications

☐ Others: _____


ACCEPTANCE

Date Recieved:


10/23/25

☒ Complete

☐ Partial



CLINT C. SARVIDA
Inspector



DOREEN B. ALBA
Head, Supply & Property Management