

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **BAYBAY PRINTSHOP**

IAR No: 25-11-1606

P.O No.: **VSU-GOODS-25-22-067-A (STF)**

Date: 2025-11-10

Office/Dept: **DOE**

49,000.00

STF-2024-10-0245

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	unit	Aircon Split Type 2.5 HP Inverter , With Installation, MATRIX MX-CS70L2A	1	1	2025-11-07 #: DR 251107A/ SI 5428	0	Completed

Specification:

Cooling Capacity:

26,375 kJ/h

Power Supply:

230 V / 60 Hz / 1 Phase

Rated Power:

2,350 W

Rated Current:

10.3 A

Energy Efficiency Ratio (EER):

11.22 kJ/h-W

Operation Temperature Range:

17°C to 30°C

Applicable Area (Unloaded Space):

32 to 47 m²

Air Volume (High/Medium/Low):

1,030 m³/h

Noise Level (Low):

38 dB(A)

Liquid Pipe Size (Diameter):

9.52 mm

Gas Pipe Size (Diameter):

15.9 mm

Maximum Refrigerant Pipe Length:

25 m

Maximum Difference in Height:

10 m

Warranty

- 1 Year on Parts & Service
- 5 Years on Compressor

Additional Information

- Free Installation included


INSPECTION

Date Inspected:

11/10/12

☒ Inspected, verified and found in order
as to quantity and specifications

☐ Others: _____


CLINT C. SARVIDA
Inspector


ACCEPTANCE

Date Recieved:

11/10/12

☒ Complete

☐ Partial


DOREEN B. ALBA
Head, Supply & Property Management