

Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte
SUPPLY & PROPERTY MANAGEMENT

INSPECTION & ACCEPTANCE REPORT

Supplier: **METRO COOLAIRE TRADING CORPORATION**

IAR No: 25-07-0824

P.O No.: **VSU-GOODS-25-22-070 (STF)**

Date: 2025-07-07

Office/Dept: **USHER**

80,000.00

STF-2024-06-01252

No.	UNIT	DESCRIPTION	Quantity		Date Received	Balance	Remarks
			Per P.O	Actual			
1	pc	Split type air-condition, Inverter, MIDEA: FP-53AST025KEIV-F4	2	2	2025-07-04 #: DR-0303	0	Completed

Specification:

Cooling Capacity:

Minimum-Maximum:

- kJ/h: 24,120
- kW: 6.70

EER (Energy Efficiency Ratio):

- kJ/hW: 11.0

Electrical Data:

Voltage:

- V: 230

Running Current:

- A: 9.6

Power Input:

- W: 2,190

Moisture Removal:

L/h:

- 3.8

Pt/h:

- 8.0

Air Circulation:

- Indoor (Hi):
 - m³/min: 52.5 (1,850)

◦ ft³/min: 20.8 (734)

Noise Level:

Indoor (Hi/Lo):

- dB-A: 47/42

Outside (Hi):

- dB-A: 60

Dimensions:

Height:

- mm: 302 (695)
- inch: 11-29/32 (27-3/8)

Width:

- mm: 1,102 (875)
- inch: 43-13/32 (32-15/32)

Depth:

- mm: 244 (220)
- inch: 9-5/8 (12-5/8)

Net Weight:

kg:

- 12 (26)

lb:

- 54 (119)

Refrigerant:

Liquid Side Pipe Diameter:

- mm: 6.35
- inch: 1/4

Gas Side Pipe Diameter:

- mm: 12.70
- inch: 5/8

Pipe Extension:

Chargeless Pipe Length:

- m: 7.5

Maximum Pipe Length:

- m: 20

Maximum Elevation Length:

- m: 15

Additional Refrigerant Gas:

- g/m: 10

Power Supply:

- Outdoor

INSPECTION *2/2/15*

ACCEPTANCE *2/2/15*

Date Inspected:

Date Recieved:

- ☐ Inspected, verified and found in order
as to quantity and specifications

☒ Complete

☐ Others: _____

☐ Partial

[Signature]
CLINT C. SARVIDA
Inspector

[Signature]
VIVIAN V. BALBARINO
Head, Supply & Property Management